#### **₽EMKO**

## PROCESS CONTROL UNITS FSM-XX30



(€ €

ESM-4430, ESM-7730, ESM-9930, ESM-4930, ESM-9430 Universal Input PID Process Controllers

- 4 digit process (PV) and 4 digit set (SV) display
- Universal process input (TC, RTD, mV ==, V ==, mA ==)
- Programmable ON/OFF, P, PI, PD and PID control forms
- Auto-tune and Self-tune PID
- Manual/Automatic mode selection for control outputs
- Bumpless transfer
- Programmable heating, cooling and alarm functions for control outputs

### SPECIFICATIONS PROCESS INPUT

 $\begin{array}{l} \textbf{Universal Input:} \ TC, \ RTD, === \ Voltage/Current \\ Thermocouple \ (TC): \ L(DIN 43710) \ ,J \ ,K \ ,R \ ,S \ ,T \ ,B \ ,E \ and \ N \ (IEC584.1)(ITS90) \ ,C \ (ITS90) \end{array}$ 

Thermoresistance (RTD): PT-100 (IEC751)(ITS90)

Input: mV. V. mA

**Measurement Range :** Please refer to Table-1 for selection of input type and scale

Accuracy:± 0.25% of full scale for thermocouple, thermoresistance, mV, V and mA input.

Cold Junction Compensation: Automatically ±0.1°C/1°C

Line Compensation: Maximum 10 Ohm

Sensor break protection: Upscale

Sampling Cycle:3 samples per second

Input Filter: 0.0 to 900.0 seconds

CONTROL

**Control Form:** ON/OFF, P, PI, PD or PID (Control form can be programmed by the user)

#### OUTPU

Standard Relay Outputs: Two relays. 5A@250V~(at resistive load) (They can be programmed as Control or Alarm output)

SSR Driver Output: Maximum 20mA@18V \_\_\_

#### SUPPLY VOLTAGE

100-240 V  $\sim$  50/60 Hz (-15%;+10%), - 6VA 24V  $\sim$  50/60 Hz (-15%; +10%), - 6VA 24V == (-15%; +10%), - 6W (Must be determined in order)

#### DISPLAY

#### Process Display:

ESM-4430: 10.1 mm Red 4 Digits LED Display ESM-4930: 13.2 mm Red 4 Digits LED Display ESM-7730: 13.2 mm Red 4 Digits LED Display ESM-9930: 19 mm Red 4 Digits LED Display ESM-9430: 10.1 mm Red 4 Digits LED Display

#### Set Value Display:

ESM-4430 : 8 mm Green 4 Digits LED Display ESM-4930 : 8 mm Green 4 Digits LED Display ESM-9730 : 9.1 mm Green 4 Digits LED Display ESM-9930 : 10.8 mm Green 4 Digits LED Display ESM-9430 : 8 mm Green 4 Digits LED Display

ESM: 9430 . 3 min Green 4 Digits LED Display
LEDS : ATCAuto Tune), M (Manual Mode), A (Automatic Mode),
PSET / ASET1 / ASET2 (Control or Alarm Set) Leds, PO, AO1, AO2

(Control or Alarm Status) °C / °F / V Leds

#### **ENVIRONMENTAL RATINGS and PHYSICAL SPECIFICATIONS**

Operating Temperature: 0...50°C Humidity: 0-90%RH (none condensing) Protection Class: IP65 at front, IP20 at rear Weight:

ESM-4430 : 170 gr

ESM-4930 : 230 gr. ESM-7730 : 230 gr. ESM-9930 : 320 gr. ESM-9430 : 230 gr.

Dimensions:

ESM-4430 : (48 x 48mm, Depth:87.5 mm) ESM-4930 : (96 x 48mm, Depth:86.5 mm) ESM-7730 : (72 x 72mm, Depth:87.5 mm)

ESM-9930 : (96 x 96mm, Depth:87.5 mm) ESM-9430 : (48 x 96mm, Depth:86.5 mm)


#### Panel Cut-Out:


ESM-4430 : (46 x 46mm) ESM-4930 : (92 x 46mm)


ESM-7730 : (69 x 69mm) ESM-9930 : (92 x 92mm)


ESM-9430 : (46 x 92mm)


#### Electrical Wirings



























- 1-Before mounting the device in your panel, make sure that the panel cut-out is suitable.
- 2-Check front panel gasket position
- 3-Insert the device through the cut-out. If the mounting clamp are on the unit, put out them before inserting the unit to the panel.
- 4-Insert the unit in the panel cut-out from the front side.
- 5- Insert the mounting clamps to the holes that located top and bottom sides of device and screw up the fixing screws until the unit completely immobile within the panel

Introduction Brochure. ENG ESM-XX30 01 V03 06/11




3 4 5 6 7 8 9 10 11 12




Pid ConF: PID Configuration Parameters	o - db PROPORTIONAL BAND SHIFTING	(CLL) Alama 4 Tura	
PROPORTIONAL BAND (0.0, 999.9)%  If UPL = 1000 °C, LoL = 0 °C and P = 50.0 then	((-SCALE HIGH POINT / 2), (SCALE HIGH POINT / 2)) Unit If cooling function is performed; Cooling process set value is calculated by adding set value [55£] with parameter [c_db]	Alarm-1 Type  Determines alarm type for Output-1. Active if logic output function of Alarm-1 Output is alarm output.	RoF? Alarm-2 Off Delay Time (0, 9998) Second When the value is greater than 9998, [LET] is seen on the screen. It means alarm latching output is selected. Active if logic output function of Alarm-2 Output is alarm output.
Proportional Band = (	Control form can be ON/OFF or PID.  If set value for heating = PSEL + SUOF; Then set value for cooling = PSEL + SUOF + O-db  SENSOR BREAK OUTPUT VALUE (FOR HEATING PID .0, 100.0)% (FOR COOLING PID -100.0, 0.0)%	Process high alarm Process low alarm Deviation high alarm Deviation low alarm Deviation band alarm	Alarm-2 Stabilization Time (0, 99)Second Active if logic output function of Alarm-2 Output is alarm output. After the unit is power-on and Alarm Stabilisation Time is expired, if an alarm condition which is selected with Alt2 is present, then Alarm-2 output becomes active.
DERIVATIVE TIME (0.0, 999.9)Second  Can be changed by the user. After complated the tunning correctly, integral time value changes automatically. If it is 0, derivative control is deactivated.	When sensor breaks, controlling of the process can continue by entering %output value to [5bau] parameter. If this parameter 0.0, process control output does not perform an output when sensor breaks.	S Deviation range alarm  REH: Alarm-1 hysteresis value(Scale 0%, Scale 50%)Unit  Active if logic output function of Alarm-1 Output is alarm	Gen ConF: General Parameters
CONTROL PERIOD TIME (1, 150)Second Process output period time	5588 Soft Start Set value (0, 9999)Unit	output.	Process Set Value Low Limit (Scale Low Point, 50-0)Unit
©!. MINIMUM CONTROL OUTPUT (0.0, ov.)%  Even as a result of the PID calculation device calculates the %output value less than this parameter, heating or cooling output is active minimum for OLL parameter.	When the device power on, if the Soft start set value different from "0", and temperature value is lower than soft start value on heating processes, device starts soft start operation, until temperature reaches soft start set value. On soft start device output period will be SSCt parameter value and device control	Alarm-1 On Delay Time (0, 9999)Second Active if logic output function of Alarm-1 Output is alarm output.    RoF   Alarm-1 Off Delay Time (0, 9998)Second	「ラジー」 Process Set Value Up Limit ( 「ラジー」, Scale High Point)Unit Pっと
Even as a result of the PID calculation device calculates the %output value greater than this parameter, heating or cooling output is active maximum for OUL parameter.	output will be SSCo parameter value.  [55[] Soft Start Control Output (10.0, 90.0)%	When the value is greater than 9998, LETH is seen on the screen. It means alarm latching output is selected. Active if logic output function of Alarm-1 Output is alarm output.    REST   Alarm-1 Stabilization Time (0, 99)Second	o Alarm Set values can be changed S Alarm Set values can not be changed. Alarm set values parameters, মি and মি , are not accessible
OLE MINIMUM CONTROL OUTPUT TIME (0.0, [E]) Second	Soft Start Control Period (0, 100)Second	Active if logic output function of Alarm-1 Output is alarm output.  After the unit is power-on and Alarm Stabilisation Time is	Pr는근 AUTO / MANUAL Selection Button Protection
Heating or cooling output can not be active less than this parameter. Even if this parameter is 0, this parameter is accepted as 50 msecs.	PCnF ConF: Process Output Configuration Parameters	expired, if an alarm condition which is selected with Alt1 is present, then Alarm-1 output becomes active.	Auto or Manual selection is possible with A/M button in Main Operation screen
ANTI-RESET WINDUP (0, SCALE HIGH POINT)Unit While PID operation is running if	Output Configuration  Determines if Process Output (SSR Driver Output ) and Alarm-2		년55 Auto or Manual selection is not possible with A/M button in Main Operation screen
PSEE - Rr <= process value <= PSEE + Rr condition is true, integral value is calculated. If the condition is not true, integral value is not calculated and last calculated integral value is used.	Output operates together or not.  Process Output (SSR Driver Output) and Alarm-2 Output operates separately.  Process Output (SSR Driver Output) and Alarm-2 Output	Aln2 Conf: Alarm-2 Output Configuration Parameters  *Aln2 Conf" Menu is accessible if Told parameter in "PCnF Conf" is Told Parameter in "PCnF".	AT (AUTO TUNE) Button Protection  Limit Cycle Tuning operation can be activated or deactivated with AT (Auto Tune) Button in Operation screen
SUOF SET VALUE OFFSET	operates together. Alarm functions of Alarm-2 Output can not be used	[ຼວບ∂ Logic Output-2	년5 Limit Cycle Tuning operation can not be activated or deactivated with AT (Auto Tune) Button in Operation screen
((-SCALE HIGH POINT/2), (SCALE HIGH POINT/2))Unit  [PSE] + [SUOF] is used as set value in PID calculations. This	oFn[ Process Output Function	Determines logic output function for Alarm-2 Output	dedouvated with it (video ratio) Button in operation concern
parameter is used for shifting the proportional band.  [PoF5] PID OUTPUT OFFSET	HERE Heating	Alarm output	PASS ConF: Password Parameters
(FOR HEATING PID 0.0, 100.0)% (FOR COOLING PID -100.0, 0.0)%	[[oot] Cooling [[논맛위 Process Output Control Type	Manual / Automatic selsction output  Sensor break alarm output	단면의 Technician Password (0, 9999)
This parameter is added to "Output %" which is calculated at the end of the PID.	onoF ON/OFF control algorithm	Output is active when the process value is out of the band which is defined with minimum value of operating scale	Uses for protecting and accessing to the technician parameters.
Poss Output offset related to PID SET	P.J PID control algorithm	<u>ਿਹ ।</u> and maximum value of operating scale <u>ਹੈ ।</u>	If this parameter is ① ; there is no password protection while entering to the technician parameters.
(FOR HEATING PID 0.0, 100.0)% (FOR COOLING PID -100.0, 0.0)%	Hysteresis of Process Output (Scale 0%, Scale 50%)Unit Active if ON/OFF control is selected.	RL는 2 Alarm-2 Type	If this parameter is different from " 0" and user wants to
This parameter is added to the %process output that is calculated at the end of the PID according to process set value. $POSD * PSE / (UPL - UO)$	Operation form of hysteresis Active if ON/OFF control is selected.	Determines alarm type for Output-2. Active if logic output function of Alarm-2 Output is alarm output.	access to the technician parameters;  1-if technician does not enter [ [ P ] password correctly: It turns to operation screen without entering to technician
Stra PROCESS VALUE STABILIZATION (1, SCALE HIGH POINT)Unit	① SV + HYS/2 and SV - HYS/2 ② SV and SV + HYS or SV and SV - HYS	Process low alarm	parameters.
It is used for controlling if process value oscillates or not when Lunn Parameter is Runn or RESE If;  PSEE - SERN <= Process Value <= PSEE + SERN condition is not true, then device start tunn operation automatically.	OFF Time (0.0, 100.0)Second In ON/OFF operation, this time must be passed for the output to be energised again. (Active if ON/OFF control is selected)	2 Deviation high alarm 3 Deviation low alarm 4 Deviation band alarm 5 Deviation range alarm	2-When  [P] in top display and  in bottom display, if technician presses SET button without entering  password (For observing parameter) Technician can see all menus and parameters except Technician Password menu ("Pass Conf"), but parameters can not be changed.
SCALE LOW POINT: Minimum process input value in Pt-100 and Tc inputs1999 for fixed dual point display adjustment used inputs, Scale low point is the lowest one from [Fo_L] or [Fo_H] for selectable dual point display adjustment used inputs Scale low point is the lowest one from [Fo_U] or Fo_H for multipoint display adjustment used inputs	Aln1 ConF: Alarm Output-1 Configuration Parameters  Logic Output-1  Determines logic output function for Alarm-1 Output  Alarm output  Manual / Automatic selection output	Alarm-2 hysteresis value(Scale 0%, Scale 50%)Unit Active if logic output function of Alarm-2 Output is alarm output.  Ron? Alarm-2 On Delay Time (0, 9999)Second	Carrier De Orientycu.
SCALE HIGH POINT: Maximum process input value in Pt-100 and Tc inputs. 9999 for fixed dual point display adjustment used inputs, Scale high point is the biggest one from Foot or Foot for selectable dual point display adjustment used inputs Scale high point is the biggest one from Foot or Foot for multi point display adjustment used inputs	Sensor break alarm output  Output is active when the process value is out of the band which is defined with minimum value of operating scale  LoL and maximum value of operating scale	Active if logic output function of Alarm-2 Output is alarm output.	

#### Alarm Types


#### Process high alarm




#### Process low alarm




#### Deviation high alarm



#### Deviation low alarm




#### **Deviation Band Alarm**



Process Value

#### **Deviation Range Alarm**



#### Failure message in ESM-XX30 Process Controllers



1 - Sensor failure in analogue input. Sensor connection is wrong or there is no sensor connection.











4 - If technician password is different from "0" and technician accesses to the parameters by Set button without entering the technician password and wants to change a parameter, device does not allow to do any changes in parameters. If increment or decrement button is pressed, a warning message will appear on the bottom display as shown on the left.



AT AM SET

**5** - If tuning operation can not be completed in 8 hours, AT led starts to blink.Blinking can be canceled by pressing Enter button.

#### Installation



Before beginning installation of this product, please read the instruction manual and warnings below carefully.

In package,

- One piece unit
- Two pieces mounting clamp
- One piece instruction manual

A visual inspection of this product for possible damage occured during shipment is recommended before installation. It is your responsibility to ensure that qualified mechanical and electrical technicians install this product.

If there is danger of serious accident resulting from a failure or defect in this unit, power off the system and separate the electrical connection of the device from the system.

The unit is normally supplied without a power switch or a fuse. Use power switch and fuse as required.

Be sure to use the rated power supply voltage to protect the unit against damage and to prevent failure.

Keep the power off until all of the wiring is completed so that electric shock and trouble with the unit can be prevented.

Never attempt to disassemble, modify or repair this unit. Tampering with the unit may results in malfunction, electric shock or fire.

Do not use the unit in combustible or explosive gaseous atmospheres. During the equipment is putted in hole on the metal panel while mechanical installation some metal burrs can cause injury on hands, you must be careful.

Montage of the product on a system must be done with it's mounting clamp. Do not do the montage of the device with inappropriate mounting clamp. Be sure that device will not fall while doing the montage.

It is your responsibility if this equipment is used in a manner not specified in this instruction manual.

#### Warranty

EMKO Elektronik warrants that the equipment delivered is free from defects in material and workmanship. This warranty is provided for a period of two years. The warranty period starts from the delivery date. This warranty is in force if duty and responsibilities which are determined in warranty document and instruction manual performs by the customer completely.

#### Maintenance

Repairs should only be performed by trained and specialized personnel. Cut power to the device before accessing internal parts. Do not clean the case with hydrocarbon-based solvents (Petrol, Trichlorethylene etc.). Use of these solvents can reduce the mechanical reliability of the device. Use a cloth dampened in ethyl alcohol or water to clean the external plastic case.

#### Other Informations

#### Manufacturer Information:

Emko Elektronik Sanayi ve Ticaret A.Ş. Demirtaş Organize Sanayi Bölgesi Karanfil Sk. No:6 16369 BURSA

Tel: (224) 261 1900 Fax: (224) 261 1912

#### Repair and maintenance service information:

Emko Elektronik Sanayi ve Ticaret A.Ş. Demirtaş Organize Sanayi Bölgesi Karanfil Sk. No:6 16369 BURSA

Tel: (224) 261 1900 Fax: (224) 261 1912

# Ordering Information ESM-4430 (48x48 DIN 1/16) ESM-4930 (98x48 DIN 1/8) ESM-730 (72x72 DIN Size)

# ESM-9930 (sesse bin 14) ESM-9430 (sesse bin 14) ESM-9430 (sesse bin 14) A Supply Voltage 1 100-240V ~ (-15%;+10%) 50/60Hz 2 24V ~ (-15%;+10%) 50/60Hz 2 24V ~ (-15%;+10%) 50/60Hz 9 Customer (Maximum 240V ~ (-15%;+10%))50/60Hz

вс	Input Type	Scale
20	Configurable(Table-1)	Table-1

D Serial Communication

#### 0 None

0 None

#### E Output-1 (Alarm)

1 Relay Output (5A@250V~ at resistive load)

#### FG Output-2 (Process or Alarm)

01 Relay Output (5A@250V~ at resistive load)

#### HI Output-3 (Process)

02 SSR Driver Output (Maximum 20mA@18V ===)

#### Table-1

BC	Input Type(TC)	Scale(°C)	Scale(°F)
21	L ,Fe Const DIN43710	-100°C,850°C	-148°F ,1562°F
22	L ,Fe Const DIN43710	-100.0°C,850.0°C	-148.0°F,999.9°F
23	J ,Fe CuNi IEC584.1(ITS90)	-200°C,900°C	-328°F,1652°F
24	J ,Fe CuNi IEC584.1(ITS90)	-199.9°C,900.0°C	-199.9°F,999.9°F
25	K ,NiCr Ni IEC584.1(ITS90)	-200°C,1300°C	-328°F,2372°F
26	K ,NiCr Ni IEC584.1(ITS90)	-199.9°C,999.9°C	-199.9°F,999.9°F
27	R ,Pt13%Rh Pt IEC584.1(ITS90)	0°C,1700°C	32°F,3092°F
28	S ,Pt10%Rh Pt IEC584.1(ITS90)	0°C,1700°C	32°F,3092°F
29	T ,Cu CuNi IEC584.1(ITS90)	-200°C,400°C	-328°F,752°F
30	T ,Cu CuNi IEC584.1(ITS90)	-199.9°C,400.0°C	-199.9°F,752.0°F
31	B ,Pt30%Rh Pt6%Rh IEC584.1(ITS90)	44°C,1800°C	111°F,3272°F
32	B ,Pt30%Rh Pt6%Rh IEC584.1(ITS90)	44.0°C,999.9°C	111.0°F,999.9°F
33	E ,NiCr CuNi IEC584.1(ITS90)	-150°C,700°C	-238°F,1292°F
34	E ,NiCr CuNi IEC584.1(ITS90)	-150.0°C,700.0°C	-199.9°F,999.9°F
35	N ,Nicrosil Nisil IEC584.1(ITS90)	-200°C,1300°C	-328°F,2372°F
36	N ,Nicrosil Nisil IEC584.1(ITS90)	-199.9°C,999.9°C	-199.9°F,999.9°F
37	C, (ITS90)	0°C,2300°C	32°F,3261°F
38	C, (ITS90)	0.0°C,999.9°C	32.0°F,999.9°F
вс	Input Type(RTD)	Scale(°C)	Scale(°F)
39	PT 100 , IEC751(ITS90)	-200°C,650°C	-328°F,1202°F
40	PT 100, IEC751(ITS90)	-199.9°C,650.0°C	-199.9°F,999.9°F

BC	Input Type( === Voltage and Current)	Scale
41	050 mV ===	-1999,9999
42	05 V ===	-1999,9999
43	010 V ===	-1999,9999
44	020 mA ====	-1999,9999
45	420 mA ====	-1999,9999